

From: formpost@contensis.co.uk
Sent: 14 February 2020 12:54
To: Neighbourhood Planning
Subject: [EXTERNAL] Comment form submitted: Great and Little Kimble-cum-Marsh NP

Contensis Email Notification



Project - Website

<https://cms-wycombedc.cloud.contensis.com/>

A new form post has been received.



Posted on: 14/02/2020 12:53:37
Posted from: <https://www.wycombe.gov.uk/pages/About-the-council/Have-your-say/Consultation-forms/Comment-form-Great-and-Little-Kimble-cum-Marsh-Neighbourhood-Plan.aspx>

Form Post

Name: Simon Harkins
Job title (if releaveant): Network Support Assistant
Organisation (if relevant): SGN
[REDACTED]
[REDACTED]
[REDACTED]
Name: n/a n/a
Job title (if releaveant): n/a
Organisation (if relevant): n/a
Address: n/a, n/a, n/a, n/a, n/a, n/a
Email: na@na.com
Phone: n/a
Which of the following do you consider yourself (please choose only one):: Other (please specify)
Other: Utility Company
Which part(s) of the Great and Little Kimble-cum-Marsh neighbourhood plan do your comments relate to?: Developments
Which part of the basic conditions do your comments relate to? (Please tick all that apply.): The achievement of sustainable development, General conformity with the strategic policies contained in the development plan area
I work as part of SGN the gas transporter. Part of my role is to review potential developments and their impact to the gas infrastructure. Regarding the housing site allocations in the Great and Little Kimble-cum-Marsh Neighbourhood Plan, there is gas infrastructure in close vicinity to all these sites if they were looking to connect to connect to the gas
Comments:

network. The gas network is made up of different tiers; low, medium, intermediate and high. All these sites are likely to connect off the low pressure tier, but also have an impact on the medium pressure tier as well. At present there is capacity on the medium tier network for all sites, therefore no reinforcement would be required. On the low pressure tier, reinforcement is very much dependent on where the connection to the gas network would be and the size of demand for the development in question. It is recommended that for each site the developer puts in a connection request to SGN as early as possible to avoid the risk of SGN being a blocker to development.

Your privacy:

I confirm I have read and understood the Wycombe District Council privacy policy found at www.wycombe.gov.uk/privacy

Properties

Form Reference: FRM78475
Posted by: Public User (publicuser@contensis.co.uk)
IP Address: 10.65.17.8
Posted on: 14/02/2020 12:53:37
Posted from: <https://www.wycombe.gov.uk/pages/About-the-council/Have-your-say/Consultation-forms/Comment-form-Great-and-Little-Kimble-cum-Marsh-Neighbourhood-Plan.aspx>
Marked as Read: No ([Mark this post as read](#))
Form template: /SiteElements/forms/Consultation-forms/Consultation-Great-and-Little-Kimble-neighbourhood-plan.frm

This automated email has been sent from Contensis Content Management System. Any statements made, or intentions expressed in this communication may not necessarily reflect the view of Contensis. The information contained in this e-mail is confidential. It is intended only for the addressee. If you are not the addressee you must not disclose, copy or distribute this or take any action in reliance upon it. If you receive this e-mail in error, please notify your system administrator.

WARNING: Please ensure that you have adequate virus protection in place before you open or detach any documents attached to this e-mail.

Click [here](#) to report this email as spam.